

State of Utah
Department of Natural Resources
Division of Water Rights

Washington
JUN 06 1978
WATER RIGHTS

MUNICIPAL AND DOMESTIC WATER USE REPORT FOR 1977
(Please complete and return by March 15th)

Name of system Leeds Domestic Water Users Association

Owner of system Same as above

Address P. O. Box 627, Leeds, Utah 84746

Name and title of person completing report W. W. Schweer, Member of Board, Leeds Domestic Water Users Association

A. System history and requirements

1. New service connections added during 1977 Nine taps added during 1977
2. Total of all service connections at end of 1977 94 taps
3. What percent of the total service connections are metered? 100%
4. Total amount of water used during 1977 23,673,800 gal.
(Please state if amount shown is in acre-feet, cubic feet, or gallons.)
5. Date when peak-day demand occurred Not known accurately as readings are by volunteers and taken only the 1st of each month. This occurred about 1 June 1977
6. Peak-day amount used during 19 Unknown
(Please state if amount shown is in cubic feet per second, gallons per minute, etc. Identify the units.)

a. Was this peak-day amount

(1) Only the quantity of water delivered to the distribution reservoir from all sources, or

(2) Does it include a withdrawal from the distribution system reservoir storage?

(Check which one applies.)

7. Give the total storage capacity of your distribution reservoir in acre-feet or cubic feet or gallons. (Please indicate which volume measurement you are using.) Leeds tank 60,000 gal., Silver Reef tank 30,000 gal., and fire service tank 145,000 gal. Total 235,000 gal.
8. Are master meters installed between the intake or diversion and the distribution reservoir? No

(State yes or No)

9. Are master meters installed between your distribution reservoir and the distribution system? Yes, except fire service reservoir is below master meter

(State Yes or No)

- b. Remarks (new sources, meter trouble, etc.) Silver Reef distribution point is being improved and will have a better meter soon

(OVER)